


OFFICIAL ANNOUNCEMENT
Product Change Notification



PCN #: PCN022

Date: September 16th, 2011

Synopsis: New Enclosure for L-TERM / Neues Gehäuse für L-TERM

Type of change: Software: **no** Hardware: **yes** Documentation: **yes**


Product Affected: LT-33, LT-13, LT-03, LT-04, LT-B4

Firmware version: No change / Keine Änderung

Effectivity: Transition to new enclosure starts Q4/2011
Lieferung der neuen Gehäuse erfolgt ab Q4/2011

Contents of Change:

The enclosure of the product will be changed. The connectors will be replaced with pluggable connectors. The new enclosure has a much better flammability rating of UL 5VA. The new enclosure is a full replacement in form, fit and function with a slightly wider enclosure. The width of the new enclosure is 27mm compared to 17.5mm of the current enclosure.



Action required:

Please update your documentation with new enclosure dimensions.

generated by
Change Control Board (CCB)
LOYTEC electronics GmbH

.....
(document transmitted by Email, valid without signature)