

**Date:** March 27, 2026

**Vendor Name:** LOYTEC electronics GmbH

**Product Name:** LWEB-900 Integrated Building Management System

**Product Model Number:** LWEB-900

**Applications Software Version:** V4

**Firmware Revision:** 4.6

**BACnet Protocol Revision:** 135-2024 (1.16)

### **Product Description:**

This product implements a BACnet operating workstation for the PC platform based on BACnet/IP. LWEB-900 can discover BACnet devices in the BACnet network and allows an operator to view and manipulate BACnet properties, both standard and custom ones, in real time. An operator can retrieve and graphically view alarming, scheduling, and trending information of BACnet devices. This information can be included in reports, which may be generated periodically or manually. LWEB 900 features BACnet time master functionality and supports BACnet backup and restore.

### **BACnet Standardized Device Profile (Annex L):**

BACnet Operating Workstation (B-OWS)

### **BACnet Interoperability Building Blocks Supported (Annex K):**

Data Sharing-ReadProperty-A (DS-RP-A)  
Data Sharing-ReadProperty-B (DS-RP-B)  
Data Sharing-ReadPropertyMultiple-A (DS-RPM-A)  
Data Sharing-ReadPropertyMultiple-B (DS-RPM-B)  
Data Sharing-WriteProperty-A (DS-WP-A)  
Data Sharing-WritePropertyMultiple-A (DS-WPM-A)  
Data Sharing-View-A (DS-V-A)  
Data Sharing-Modify-A (DS-M-A)  
Alarm and Event-Notification-A (AE-N-A)  
Alarm and Event-Management-View Notifications-A (AE-VN-A)  
Alarm and Event-ACK-A (AE-ACK-A)  
Alarm and Event-Alarm Summary-A (AE-ASUM-A)  
Alarm and Event-Enrollment Summary-A (AE-ESUM-A)  
Alarm and Event-Information-A (AE-INFO-A)  
Alarm and Event Management-View Notifications-A (AE-VN-A)  
Alarm and Event Management-View and Modify-A (AE-VM-A)  
Alarm and Event Management-Alarm Summary-View-A (AE-AS-A)  
Scheduling-View and Modify-A (SCHED-VM-A)  
Trending-View-A (T-V-A)  
Device Management-DynamicDeviceBinding-A (DM-DDB-A)  
Device Management-DynamicDeviceBinding-B (DM-DDB-B)  
Device Management-DynamicObjectBinding-B (DM-DOB-B)  
Device Management-Manual Time Synchronization-A (DM-MTS-A)  
Device Management-TimeSynchronization-A (DM-TS-A)  
Device Management-UTCTimeSynchronization-A (DM-UTC-A)  
Device Management-Automatic Time Synchronization-A (DM-ATS-A)  
Device Management-ReinitializeDevice-A (DM-RD-A)  
Device Management-Backup and Restore-A (DM-BR-A)  
Device Management-Restart A (DM-R-A)

**Segmentation Capability:**

Segmented requests supported, window size: 4  
Segmented responses supported, window size: 4

**Standard Object Types Supported:**

For all object types below the following applies if not stated otherwise:

- 1) Objects cannot be created via CreateObject and DeleteObject services.
- 2) Object\_Name, Description support up to 64 characters.
- 3) All required properties exist as specified for the object type.
- 4) No additional writeable properties exist.
- 5) No proprietary properties exist.
- 6) No range restrictions exist.

**Device Object**

*List of optional properties supported:*

Description, Max\_Segments\_Accepted, APDU\_Segment\_Timeout, Active\_COV\_Subscriptions, Local\_Time, Local\_Date, UTC\_Offset, Daylight\_Saving\_Status, Time\_Synchronization\_Recipients, UTC\_Time\_Synchronization\_Recipients, Time\_Synchronization\_Interval, Align\_Intervals, Interval\_Offset,

**Data Link Layer Options:**

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), BACnet Broadcast Management Device (BBMD)
- BACnet IP, (Annex J), Network Address Translation (NAT Traversal)
- BACnet IPv6, (Annex U)
- BACnet IPv6, (Annex U), BACnet Broadcast Management Device (BBMD)
- BACnet/ZigBee (Annex O)
- Ethernet, ISO 8802-3 (Clause 7)
- LonTalk, ISO/IEC 14908.1 (Clause 11)
- MS/TP (Clause 9)
- Point-To-Point, EIA 232 (Clause 10)
- Point-To-Point, modem (Clause 10)
- BACnet Secure Connect (Annex AB)

**Device Address Binding:**

Static device address binding is not supported.

**Networking Options:**

- Router, Clause 6
- Annex H, BACnet Tunneling Router over IP

**Character Sets Supported:**

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4/UTF-8
- IBM™/Microsoft™ DBCS
- ISO 8859-1
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS C 6226

**Gateway Options:**

The device is not a communication gateway.

**Additional Information and Contact:**

Further Information, a detailed User Manual and firmware updates can be obtained from our website  
<http://www.loytec.com>.

For information and technical support please contact us at the following address:

*LOYTEC electronics GmbH.  
Blumengasse 35  
A-1170 Vienna  
Austria / Europe*

*email: [support@loytec.com](mailto:support@loytec.com)  
web: <http://www.loytec.com>  
tel: +43/1/40208050  
fax: +43/1/402080599*